



Certificate / Certificat Zertifikat / 合格証

COW 1505085 C004

exida hereby confirms that the:

Series CSY Rotary Actuator

The manufacturer
may use the mark:



Revision 1.0 July 12, 2019
Surveillance Audit Due
January 1, 2022

Cowan Dynamics Inc. Montreal, QC - Canada

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The actuators will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



ANSI Accredited Program
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004



Evaluating Assessor

Certifying Assessor

COW 1505085 C004

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFD_{avg} and Architecture Constraints
must be verified for each application**

Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Application/Device/Configuration	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Spring Return	0	100	0	439
Dual Acting	0	0	0	412
Spring Return with PVST	99	1	260	179
Dual Acting with PVST	0	0	248	164

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: COW 15-05-085 R004 V2R1 (or later)

Safety Manual: SIL Safety Guide-Series CSY, Rev 0 (or later)



80 N Main St
Sellersville, PA 18960